



Capillary Ultrafiltration Module HYDRAcap60

Performance[†] $11 - 30 \text{ gpm } (2.7 - 6.8 \text{ m}^3/\text{h})$ Filtrate Flow:

Filtrate Turbidity: ≤ 0.07 NTU Virus removal ≥ 4 log Bacteria removal ≥ 4 log 5 - 65%**TOC Reduction**

Type Capillary Ultrafiltration Module Configuration:

Membrane Polymer: Hydrophilic Polyethersulfone 150.000 Daltons MWCO, nominal Nominal Membrane Area: 500 ft² (46 m²) 13,200 Number of Fibers:

Fiber Dimensions:

ID 0.031" (0.8 mm), OD 0.051" (1.3 mm)

Application Data[‡] Typical Filtrate Flux Range: $35 - 85 \text{ gfd } (59 - 145 \text{ l/m}^2/\text{h})$

Maximum Applied Feed Pressure: 73 psig (5 bar) Maximum Transmembrane Pressure 20 psig (1.4 bar) Maximum Backwash Transmembrane Pressure: 20 psig (1.4 bar)

100 ppm. Instantaneous Chlorine Tolerance:

Instantaneous Hydrogen Peroxide Tolerance: 200 ppm² Maximum Chlorine Exposure: 200,000 ppm-hrs

Maximum Instantaneous Feed Turbidity: 100 NTU Maximum Operating Temperature: 104 °F (40 °C) pH Operating Range: 4.0 - 10.0

Cleaning pH Range: 1.5 - 13.0Operating Mode: Inside to Outside Filtration


Direct flow or Crossflow

Typical Process Conditions

 $100 - 150 \text{ gfd } (170 - 255 \text{ l/m}^2/\text{h})$ Backwash Flux:

Backwash Duration: 30 - 60 seconds Backwash Frequency: 20 - 60 minutes Chemical Enhanced Backwash Frequency: 0 - 4 times per day Chemical Enhanced Backwash Duration: 1 – 30 minutes

Disinfection Chemicals: NaOCI, H₂O₂, CIO₂ or NH₂CI Cleaning Chemicals: HCI, H₂SO₄, NaOH or Citric Acid




A, inches (mm)	B, inches (mm)	C, inches (mm)	Pipe connections	Weight, Ibs. (kg) ave.
63 (1600)	66 1/8 (1680)	67 1/4 (1708)	2" Victaulic	97 (44)

Certifications: NSF61, CA-DHS and ETV-NSF Verification

[‡] The limitations shown here are for general use. The values may be more conservative for specific projects to ensure the best performance and longest life







Typical TOC rejection is 5-15% without coagulant and 40-65% with coagulant

For 15 minutes or less.

[†] Typical module performance for most feedwaters.