



**RATING:**

DESIGN PRESSURE..... 300 PSI at 120°F  
(2.1 MPa at 49°C)  
 MIN. OPERATING TEMP..... 20°F  
(-7°C)  
 FACTORY TEST PRESSURE... 450 PSIG/330PSIG  
(3.10 MPa)/(2.27MPa)  
 BURST PRESSURE..... 1800 PSI  
(12.2 MPa)

**INTENDED USE**

The Model 40S30 Fiberglass RO/UF Pressure Vessel is designed for continuous, long-term use as a housing for reverse osmosis and ultrafiltration elements in typical industrial water treatment systems at pressures up to 300 psi. Any make of 4-inch nominal diameter spiral-wound element is easily accommodated. The appropriate interfacing hardware for the element specified is furnished with the vessel.

The Model 40S30 must be installed, operated and maintained in accordance with the precautions listed and good industrial practice to assure safe operation over a long service life.

The high performance reinforced plastic shell must be allowed to expand under pressure; undue restraint at support points or piping connections can cause leaks to develop in the shell. This side-ported vessel requires special precautions in mounting and connection to piping so that the vessel will not be subjected to excessive stress due to bending moments acting at the side openings in the fiberglass shell.

The end closures, incorporating close-fitting, interlocking components, must be kept dry and free of corrosion; deterioration can lead to catastrophic mechanical failure of the heads.

Pentair Water will assist the purchaser in determining the suitability of this standard vessel for their specific operating conditions. The final determination however, including evaluation of the standard materials of construction for compatibility with the specific corrosive environment, shall be the responsibility of the purchaser. Alternate materials with enhanced corrosion resistance are available on special order.

Specifications subject to change without notice.

**PRECAUTIONS**

- DO... read, understand and follow all instructions; failure to take every precaution will void warranty and may result in vessel failure
- DO... mount shell on horizontal members at central span "S" using compliant vessel supports furnished; tighten hold down straps just snug.
- DO... align and center side ports with the manifold header; correct causes of misalignment in a row of vessels connected to the same header
- DO... use flexible type IPS grooved-end pipe couplings, at sideports; allow full .125 inch gap between port and piping, and position piping to maximize flexibility of connection
- DO... provide flexibility in, and support for piping manifold so that vessel can grow in length under pressure without undue restraint; provide additional flexible joints in large pipes leading to manifold header
- DO... provide overpressure protection for vessel set at not more than 105% of design pressure
- DO... inspect end closures regularly; replace components that have deteriorated and correct causes of corrosion
- DO NOT... work on any component until first verifying that pressure is relieved from vessel
- DO NOT... make rigid piping connections to ports or clamp vessel in any way that restricts growth of fiberglass shell under pressure; ΔDIA = 0.01 in. (0.25 mm) and ΔL = .140 in. (3.5 mm) for a length code -6 vessel
- DO NOT... hang piping manifolds from ports or use vessel in any way to support other components
- DO NOT... operate vessel at pressures and temperatures in excess of its rating
- DO NOT... operate vessel without Permeate Ports internally connected with a complete set of elements and interconnecting hardware
- DO NOT... tighten Permeate Port connection more than one turn past hand tight
- DO NOT... operate vessel with permeate pressure in excess of 125 psi at 120°F (0.9 MPa at 49°C)
- DO NOT... tolerate leaks or allow end closures to be routinely wetted in any way
- DO NOT... pressurize vessel until double checking to verify that the Retaining Rings are in place.
- DO NOT... install Spacer on downstream end of vessel

**NOTE**

Spiral Retaining Ring Removal Tool (1MM007-1) recommended to open and close vessel.

**ORDERING**

Using the chart below, please check the features you require and fax them with your purchase order to our customer service department for expedited processing. For optional materials and/or feature not listed below, please consult the factory for pricing and availability.

**VESSEL LENGTH CODE - please check one**  
 MODEL 40S30  -1  -2  -3  -4  -5  -6

**EXTERIOR FINISH -**  
 Standard - white high-gloss polyurethane coating over sanded surface.

**CERTIFICATION -**  
 Standard - certified by CodeLine, not code stamped.

**MEMBRANE BRAND AND MODEL - please check one and fill in information**

- Please supply adapters for the following membrane brand and specific model.  
 Brand \_\_\_\_\_ Model \_\_\_\_\_
- Membrane brand and model information is not currently available, but will be supplied to CodeLine on or before the following date. \_\_\_\_/\_\_\_\_/\_\_\_\_

- 
- 

**PERMEATE PORT CONFIGURATION**  
 Standard - 1/2" NPT Female (Standard per drawing)  
 Option - 1/2" BSP/JIS Female

**FEED PORT CONFIGURATION**  
 Standard - 1" IPS Grooved End, CF8M (Standard per drawing)  
 Optional - Multi-Ports™ port clogging.  
 please fill out your feed port configuration in the space below.  
 List port location first followed by port size for each choice.

Serial number end

Opposite end

PORT SIZE CODE	
<b>A</b>	3/4" NPT FEMALE
<b>B</b>	3/4" BSP/JIS FEMALE
<b>C</b>	1" GROOVED END

